



## City of Gillette

P. O. Box 3300 • Gillette, Wyoming 82716  
Phone (307) 686-6200

Department of Public Works  
Water/Wastewater Division

May 7, 1985

Mr. Spencer Cubage  
Flowmore Services Corporation  
P.O. Box 692005  
Houston, Texas 77269

Dear Spencer,

Just a note on the results of our flow tests on the fire hydrants along Ross Avenue **after** our pigging operation.

<b>Location</b>	<b>Previous Flow</b>	<b>Present Flow</b>
2nd/Ross Ave.	770 gpm	2,430 gpm
3rd/Ross Ave.	776 gpm	2,040 gpm
4th/Ross Ave.	770 gpm	1,890 gpm*

\* This hydrant only has a 4" lead.

It appears that we were successful in obtaining our minimum fire flows with no problem. Thanks for the help.

Sincerely,

A handwritten signature in blue ink, appearing to read "Ron Doba".

Ron Doba  
Water/Wastewater Supt.